



SHEET NOTES:

A. REFERENCE SHEET S00x FOR STRUCTURAL GENERAL NOTES. REVIEW NOTES & DETAILS FOR APPLICABILITY.

B. SEE ARCHITECTURAL DRAWING FOR DETAILS & DIMENSIONS NOT SHOWN.

C. REFER TO S0x FOR TYPICAL DETAILS.

D. TOP OF SLAB ELEVATION = 100'-0" UNO (THIS IS A REFERENCE ELEVATION)

E. ALL CONNECTIONS TO USE 2 BOLTS MIN.

F. ALL EXTERIOR STEEL TO BE HOT DIP GALV.

PLAN NOTES:

① 12" WIDE X 12" DEEP THICKENED SLAB @ STAIR LANDING. REINF W/ (2) #4 BOT

② HSS3X3X1/4 POSTS W/ 9" SQ X 3/8" BASE PLATE AND (4) 5/8" DIA ANCHOR RODS (9" EMBED). PROVIDE 12" DIA X 2'-0" DEEP DRILLED PIERS W/ (2) #4 VERTS IN PIERS.

③ PREFAB GRATING TREADS, RATED FOR 100 PSF AND 300 LB POINT LOAD.

④ 1.25" X 3/16" GW GRATING. FASTEN TO SUPPORTS WITH GRATING CLAMPS

⑤ PROVIDE OSHA COMPLIANT RAILINGS. USE 1.25" DIA PIPE VERTS (MIN) @ 4'-0" OC MAX

⑥ (3) 5/8" DIA GALV THREADED ROD. DRILL AND EPOXY 4" MIN INTO EXISTING CONC. PROVIDE DOUBLE NUTS ATTACHING LANDING CHANNEL TO EXISTING CONC WALL.



AMAI ARCHITECTURE
100 Greystone Avenue
Kansas City, KS 66103
P 816.994.5900 / 5901 F



**WHITE CAP
EL PASO
RENOVATION**

8650 Yermoland Dr
El Paso, TX
Project No. 22023

Consultants

ADA Consultant:
500 WESST UNIVERSITY AVENUE #363
EL PASO, TX 79968
PH: 915.588.6141

Structural consultant:
STAND STRUCTURAL ENGINEERING INC
8234 ROBINSON
OVERLAND PARK, KANSAS
PH: 913.214.2169

MEP Consultants:
BC ENGINEERS
5720 REEDER
SHAWNEE, KANSAS
PH: 913.262.1772

This drawing and/or specification is provided by the Architect as an Instrument of Service and is intended for use on this project only. All reports, drawings, specifications, computer files, notes and other documents prepared by the Architect as instruments of Service shall remain the property of the Architect. The Architect shall retain all common law, statutory and other reserved rights, including the copyright thereto.

Copyright 2021
AMAI Architecture

ISSUED FOR:
PERMIT SET 02 FEBRUARY 2022

WAREHOUSE FLOOR PLAN

S101