

	FOOTING SCHEDULE					
	MARK	WIDTH (W)	THICKNESS (T)	REINFORCEMENT		
	F1	24"	10*	3 ROWS #4 CONT, REBAR		
_	F2	36"	10*	3 ROWS #4 CONT, REBAR		
ŀ	F2 SLAB SHALL		OAD BEARING WALL	``````````````````````````````````````		

	FLOOR SLAB SCHEDULE			
MARK	DESCRIPTION			
S1	6" CONCRETE SLAB WITH FIBER MESH & 8X6-W1.4XW1.4 WWF. ON 6"-8" STONE BASE, COVERED WITH B MIL PLASTIC WAPOR BARRIER, 2" THICK R-10 DOW BOARD INSULATED FOAM BOARD UNDER SLAB WITH 1/2" THERMAL BRAKE BETWEEN WALL & SLAB.			
82	5X5X8" CONCRETE SLAB, CENTERED ON DOOR, WITH FIBER MESH & 6X8- WI AXWI A WWF, ON 6"-8" STONE BASE, SLOPE 18" PER FOOT AWAY FROM BULLIDING, 17" PREFORMED DYPANSION MATERIAL PLACED BETWEEN SLAB & FOOTING WALL.			
S3	5X10X8" CONCRETE SLAB, 10' SIDE CENTERED ON DOOR, WITH FIBER MESH & 5X5-W1 AXW1.4 MWF, ON 6'-8" STONE BASE, SLOPE 1/8" PER FOOT AWAY FROM BUILDING, 1/2" PREFORMED EXPANSION MATERIAL PLACED BETWEEN SLAB & FOOTING WALL.			

SILL PLATE ANCHORS				
ANCHOR BOLT SHALL CONFORM TO ASTM A153 CLASS C. ANCHOR BOLT AND ALL HARDWARE SHALL BE HOT-DIPPED GALVANIZED. ANCHOR BOLTS SIZED AND LOCATED PER IBC 2308.3, 1.				

FOOTING WALL SCHEDULE						
MARK	THICKNESS (TW)	REINFORCEMENT				
W1 8"		#4 CONT. REBAR WITHIN 12' FROM TOP				







NO.	DESCRIPTION	DATE
1	ADDENDUM 1	05/16/2024
2	ADDENDUM 2	06/06/202
3	ADDENDUM 3	06/14/2024
_		_
_		_
_		_
_		
_		_
_		
		_

TYRONE TOWNSHIF

TWP BUILDING

FOOTING PLAN

2023-051
04/15/2023
H.WELCH
N.BOYLE

S-001

As indicated